

Annual Drinking Water Quality Report

TX1550035

LEVI WSC

Annual Water Quality Report for the period of January 1 to December 31, 2016

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name: Jim Sheffield

Phone: (254) 857-3050

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254) 857-3050.

Sources of Drinking Water

Levi WSC is Groundwater

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

System Susceptibility Summary

Asbestos	Cyanide	Metals	Microbial	Minerals	Radiochemical	Sythetic Organic Chemicals	Disinfection Byproduct	Volatile Organic Chemicals	Drinking Water Contaminant Candidate	Other
----	----	HIGH	----	----	----	----	----	----	HIGH	----

Entry Point Susceptibility Summary

Entry Point ID	Asbestos	Cyanide	Metals	Microbial	Minerals	Radiochem	Sythetic Organic Chemicals	Disinfection Byproduct	Volatile Organic Chemicals	Drinking Water Contaminant Candidate	Other
001	----	----	HIGH	----	----	----	----	----	----	HIGH	----
002	----	----	----	----	----	----	----	----	----	----	----

INFORMATION ABOUT SOURCE WATER ASSESSMENTS

The completed TCEQ assessment of the Levi WSC source water indicate that some of the some of the sources are susceptible to certain contaminants. The sampling requirements for Levi WSC are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in the Consumer Confidence Report. For more information on water source assessments and protection efforts of the Levi System, contact Jim Sheffield, General Manager of Levi WSC.

For more information about Levi WSC sources of water, please refer to the Source Water Assessment Viewer available at:

<http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at: <http://dww.tceq.texas.gov/DWW>

Source Water Name	Type of Water	Report Status	Location
1 – 1760 Water Well Road	GW	Active	Trinity Aquifer
2 – 3502 Rosenthal Pkwy	GW	Active	Trinity Aquifer
3 – 2757 Rosenthal Pkwy	GW	Active	Trinity Aquifer

The Business Office for Levi Water Supply Corporation is located at 2757 Rosenthal Pkwy., Lorena, Texas 76655

Business Office hours: 9:00 a.m. – 12:00 p.m & 1:00 p.m. – 4:00 p.m.

The scheduled Board of Directors meeting is the 3rd Monday of each month at 6:00 p.m. at the Levi Water office.

Meeting notices are posted on www.leviwater.com an at the Levi Water office. You may also call for meeting times.

Business Office telephone: 254-857-3050 – Fax: 254-857-3226 – Email: accounts@leviwater.com

General Manager: Jim Sheffield Email: jim@leviwater.com

Emergency Contact Telephones: 254-723-1834 or 254-292-2762

2016 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/09/2015	1.3	1.3	0.069	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)

Water Quality Test Results

NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picrocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2016	2	1.5 - 1.5	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2016	8	7.7 - 7.7	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	09/09/2015	0.0357	0.0357 - 0.0357	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	09/09/2015	2.53	2.53 - 2.53	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2016	0.11	0.07 - 0.11	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	09/09/2015	3.5	3.5 - 3.5	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	09/09/2015	1.1	1.1 - 1.1	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	09/09/2015	4	4 - 4	0	15	pCi/L	N	Erosion of natural deposits.
Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Ethylbenzene	2016	1.3	0 - 1.3	700	700	ppb	N	Discharge from petroleum refineries.
Xylenes	2016	0.0064	0 - 0.0064	10	10	ppm	N	Discharge from petroleum factories; Discharge from chemical factories.

Disinfectant

Disinfectant	Year	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Likely Source of Contamination
Chlorine	2016	1.09	0.5	3.8	4	<4	ppm	N	Water additive used to control Microbes

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system [*name*] has a fluoride concentration of [*insert value*] mg/L.

Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.

Drinking water containing more than 4 mg/L of fluoride (the U.S. Environmental Protection Agency's drinking water standard) can increase your risk of developing bone disease. Your drinking water does not contain more than 4 mg/L of fluoride, but we're required to notify you when we discover that the fluoride levels in your drinking water exceed 2 mg/L because of this cosmetic dental problem.

For more information, please call Jim Sheffield at Levi Water Supply Corp. The telephone number is 254-857-3050. Email contact is jim@leviwater.com Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-877-8-NSF-HELP.